

Extinguishing System Attachments

COMPANY

SHIELD FIRE SAFETY & SECURITY LTD

Unit 3, Endeavour Dr
Basildon, SS14 3WF United Kingdom

S9078

Supervisory switches, SD-SVS-OSYJM

SPRINKLER SYSTEM ALARM INITIATING DEVICES

Wet pipe, paddle type

| Model | Size In. | Pipe Schedule | Max System Pressure psig |
|-----------|----------|---------------|--------------------------|
| SD-WFD10T | 1.00 | 10 thru 40 | 175 |
| SD-WFD12T | 1.25 | 10 thru 40 | 175 |
| SD-WFD15T | 1.50 | 10 thru 40 | 175 |
| SD-WFD20T | 2.00 | 10 thru 40 | 175 |
| SD-WFD20 | 2 | 10 thru 40 | 175 |
| SD-WFD25 | 2.5 | 10 thru 40 | 450 |
| SD-WFD30 | 3 | 10 thru 40 | 450 |
| SD-WFD40 | 4 | 10 thru 40 | 450 |
| SD-WFD50 | 5 | 10 thru 40 | 450 |
| SD-WFD60 | 6 | 10 thru 40 | 450 |
| SD-WFD80 | 8 | 10 thru 40 | 450 |
| SD-WFD100 | 10 | 10 thru 40 | 300 |
| SD-WFD-JM | 2.00 | 10 through 40 | 365 |
| | 2.5 | 10 through 40 | 365 |
| | 3.0 | 10 through 40 | 365 |
| | 4.0 | 10 through 40 | 365 |
| | 5.0 | 10 through 40 | 365 |
| | 6.0 | 10 through 40 | 365 |
| | 8.0 | 10 through 40 | 365 |

SUPERVISORY SIGNAL INITIATING DEVICES

Supervisory switches

| Model | Oper Pressure psig | Max System Pressure psig |
|--------------|--------------------|--------------------------|
| SD-SVS OSY-1 | N/A | N/A |
| SD-SVS OSY-2 | N/A | N/A |
| SD-SVS OSY-3 | N/A | N/A |
| SD-SVS IP-1 | N/A | N/A |
| SD-SVS IP-2 | N/A | N/A |
| SD-SVS IP-3 | N/A | N/A |

Trademark and/or Tradename: "SHIELD",  ,  , 

Last Updated on 2023-10-18

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2023 UL LLC."